

Option- 1

Scope of Work : Repairing of Dry Type Transformer(1000 KVA- Crompton Graves make)

SI.No	Description of Items	Qty.
1	<p><u>Specifications:-</u></p> <p>(Rewinding of 1000 KVA Dry Type 11KV/433V, 50Hz 3 phase power transformer with copper wire/strip of suitable size with proper insulation as per standard norms including dismantling the existing transformer, burnt out coils, and reinstallation, testing & commissioning etc. as required with guarantee of at least one year in full load operation.</p>	01 No

Option- 2

Scope of Work : Supply/commissioning of Dry Type Transformer(1000 KVA)

SI.No	Description of Items	Qty.
1	<p><u>Specifications:-</u></p> <p>(Supply/commissioning of 1000 KVA Dry Type 11KV/433V, 50Hz 3 phase power transformer with copper wire/strip of suitable size with proper insulation as per standard norms including dismantling the existing transformer with guarantee of at least one year in full load operation.</p> <p><u>Standard Accessories:-</u></p> <p>HV and LV Bushing with terminal connectors, Arcing horns, corrosion proof, Tap changer.</p>	01 No

Option -3

Scope of Work : Supply/commissioning of Oil Type Transformer(1000 KVA)

SI.No	Description of Items	Qty.
1	<p><u>Specifications:-</u></p> <p>11/0.4 KV, 1000 KVA, 11000/400 Volts, 50 Hz oil type indoor Transformer (standard-IEC, tapping-15%, -10%, -5%, 0, +5%, load loss-13000W, oil temp rise-50 C, 3 phase, secondary Voltage-400V, vector group- Dyn 11, cooling system-ONAN, class-A, impedance-6%, no load loss-1500W, winding temp, rise-55 C. Also, dismantling the existing transformer and with guarantee of at least one year in full load operation</p> <p><u>Standard Accessories:-</u></p> <p>HV and LV Bushing with terminal connectors, Arcing horns, corrosion proof, Tap changer , oil drain valve, lifting lugs, tank grounding provision, name plate, dehydrating breather with silica gel, liquid level gauze. etc.</p>	01 No

